

From: [KENT Mavis D](#)
To: [Shaw, Steve M.](#); [Chip Humphrey/R10/USEPA/US@EPA](#)
Subject: RE: FE/PWO Outage
Date: 06/01/2006 10:19 AM

Thanks for the update.

Mavis D. Kent
Cleanup & Emergency Response Section
DEQ Northwest Region - East Side Office
1550 NW Eastman Parkway, Suite 290
Gresham, Oregon 97030
503-667-8414 X55008
503-674-5148 Fax
kent.mavis.d@deq.state.or.us

-----Original Message-----

From: Shaw, Steve M. [<mailto:Steve.Shaw@Alcoa.com>]
Sent: Thursday, June 01, 2006 7:39 AM
To: 'Chip Humphrey/EPA10' (E-mail); KENT Mavis D
Subject: FE/PWO Outage

Chip, Mavis,
This is to let you know that we experienced an outage of the FE/PWO system for approximately 12.2 hours beginning on 5/29/06 at approximately 7:30 PM. Cause of outage is unknown. The system was restarted on 5/30/06 at approximately 8:00 AM using backup production wells 3 and 5. At approximately 3:00 PM on 5/30/06 PW 7 and 8 were returned to service after replacing blown control fuses. The back up wells were shut down.

Steven M. Shaw
Troutdale Reduction Plant
2240 NW Perimeter Way
Troutdale OR 97060
Phone 503.666.0201
Cell 503.819.6585
Fax 503.665-1049
email Steve.Shaw@Alcoa.com